

	Paper, Cloth, Wood, Rubbish, Combustibles, etc.	Volatile Liquids, Gas, Oil, Paint, etc.	Electrical Panels, Motors Apparatus, etc.	Capacity	Operating Method	Fire Fighting Agent	Approximate Horizontal Range	Approximate Discharge Time	Hydrostatic MIN Test Interval
STD Dry Chemical Powder	Surface Fires Only	Yes Excellent	Yes Excellent	2.75, 5, 10, 20, 30 LBS	Break Seal, Pull Pin, Squeeze Handle	Standard Powder	5 - 20 Feet	8 - 25 Seconds	See NFPA No. 10
A.B.C. Powder	Yes Excellent	Yes Excellent	Yes Excellent	2.75, 5, 10, 20, 30 LBS	Break Seal, Pull Pin, Squeeze Handle	All Purpose Powder	5-20 Feet	8 - 25 Seconds	See NFPA No. 10
Purple "K" Powder	Surface Fires Only	Yes Excellent	Yes Excellent	5, 10, 20, 30 LBS	Break Seal, Pull Pin, Squeeze Handle	Purple "K" Powder	5 - 20 Feet	8 - 25 Seconds	See NFPA No. 10
Water Pump Tanks	Yes Excellent	No	No	2, 4 Gallon	Operate Pump	Water	40 - 50 Feet	1 - 2 Minutes	N/A
Water Pressure	Yes Excellent	No	No	2 Gallon	Break Seal, Pull Pin, Squeeze Handle	Water	40 - 55 Feet	1 Minute	See NFPA No. 10
Carbon Dioxide	Surface Fires Only	Yes Excellent	Yes Excellent	5, 10, 20, 30 LBS	Break Seal, Pull Pin, Squeeze Handle	Carbon Dioxide	3 - 10 Feet	8 - 30 Seconds	See NFPA No. 10
Halon 1211	Yes	Yes Excellent	Yes Excellent	1, 3.5, 7, 17 LBS	Break Seal, Pull Pin, Squeeze Handle	Halon 1211	8 - 12 Feet	10 - 18 Seconds	See NFPA No. 10